



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Use with Automatic Fire Sprinkler Systems

Nordic Flow Aboveground Sprinkler Pipe Manufactured to EN 10217 Specifications

Sizes – 1, 1-1/4, 1-1/2, 2, 76.1 mm, 3, 4, 139.7 mm, 6, 8 inch NPS

For Use with Victaulic Company's Style 009N Rigid Grooved End Coupling and Titan Fire Limited Model XGQT1 Rigid Grooved End Coupling

Prepared for:

Sprinkler Nordic AB
Box 22
Knivsta 741 21
Sweden

Manufactured at:

Tecnotubi SpA
Via Mazzini 240/242
Alfianello (BS)
Italy

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: 3056298

Approval Granted: January 27, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller".

David B. Fuller
AVP - Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group